

Limited Lead in Drinking Water Assessment

Longview Public Schools Longview, Washington Broadway Learning Center



Assessment Date(s): February 21, 2022

Report Date: March 17, 2022

Prepared for: Jason Reetz, Facilities Manager
Longview Public Schools

Facility Owner/Operator: Longview Public Schools



Prepared By:
Sterling Technologies, LLC
317 NE 144th Street
Vancouver, WA 98685



Limited Lead in Drinking Water Assessment

Introduction

Sterling Technologies (Sterling) has recently completed a limited lead in drinking water screening of the Broadway Learning Center, Longview School District, located at 1410 8th Avenue in Longview, Washington. The purpose of the investigation was to identify the levels of lead in the various sources of drinking water throughout the learning center. Sample locations included drinking water fountains, classroom sink water faucets, restroom sink water faucets, and kitchen sink water faucets.

Background

The school district may be considered a water supply system from a water distribution perspective and may need to comply with the federal guidelines for water monitoring as specified in the Lead & Copper Rule (*Federal Register: June 30, 1994, Part 5. 40 CFR Parts 141 and 142; Drinking Water; Maximum Contaminant Level Goals and National Primary Drinking Water Regulations for Lead and Copper*) and may be compelled to monitor the drinking water within the district on an ongoing basis after an effective treatment approach is implemented (56FR 26460 – Lead Copper Rule). Within 30 days of learning the lead level results, all water systems (learning center in this case) must provide individual lead tap results to the people who receive water from the sites that were sampled, *regardless of whether the results exceed the Lead Action Level*, as required by 40 CFR 141.85(d).

Results Summary

Water samples were collected from 44 drinking water sources at the school.

41 samples were found to NOT contain elevated lead levels (15 ppb or higher).

3 samples were found to contain elevated lead levels (15 ppb or higher)

Sampling

The samples were collected by EPA accredited inspectors provided by Sterling. Samples included representative amounts of water. The lead in drinking water samples were analyzed by Apex Laboratories by EPA Method 200.8. The sampling guidelines followed were based on the federal school standard with emphasis on the Lead Copper Rule for sampling sites chosen.

Report continued on the next page...



Assessment Results

Analytical Results: Lead in Drinking Water

Item	Sample ID.	Location	Result (µ/L)
1	BLC-3-F	Classroom #3, Sink Faucet	0.554
2	BLC-4-F	Classroom #4, Sink Faucet	0.496
3	BLC-5-F	Classroom #5, Sink Faucet	0.689
4	BLC-5-WF	Classroom #5, Drinking Fountain	4.06
5	BLC-6-F	Classroom #6, Sink Faucet	ND
6	BLC-7-F	Classroom #7, Sink Faucet	1.41
7	BLC-8-F	Classroom #8, Sink Faucet	1.66
8	BLC-10-RR-F1	Classroom #10, Restroom Sink Faucet #1	6.71
9	BLC-10-RR-F2	Classroom #10, Restroom Sink Faucet #2	2.77
10	BLC-11-F	Classroom #11, Sink Faucet	9.02
11	BLC-12-F	Classroom #12, Sink Faucet	11.5
12	BLC-12-WF	Classroom #12, Drinking Fountain	93.2
13	BLC-13-F	Classroom #13, Sink Faucet	0.277
14	BLC-14-F	Classroom #14, Sink Faucet	17.6
15	BLC-15-F	Classroom #15, Sink Faucet	1.23
16	BLC-16-F	Classroom #16, Sink Faucet	0.768
17	BLC-18-F1	Classroom #18, Sink Faucet #1	4.47
18	BLC-18-F2	Classroom #18, Sink Faucet #2	3.56
19	BLC-18-F3	Classroom #18, Sink Faucet #3	14.7
20	BLC-19-F1	Classroom #19, Sink Faucet #1	13.9
21	BLC-19-F2	Classroom #19, Sink Faucet #2	2.29
22	BLC-19-F3	Classroom #19, Sink Faucet #3	12.1
23	BLC-19-RR-F1	Classroom #19, Restroom Sink Faucet #1	9.17
24	BLC-19-RR-F2	Classroom #19, Restroom Sink Faucet #2	17.7
25	BLC-20-F	Classroom #20, Sink Faucet	3.83
26	BLC-C-F	Custodial Closet, Sink Facuet	0.470
27	BLC-N-F	Health Office, Sink Faucet	5.38
28	BLC-K-F1	Kitchen, Sink Faucet #1	0.521
29	BLC-K-F2	Kitchen, Sink Faucet #2	3.65
30	BLC-K-F3	Kitchen, Sink Faucet #3	4.90
31	BLC-L-F	Staff Lounge, Sink Faucet	0.408
32	BLC-SRR-F	Staff Restroom, Sink Faucet	1.11

ND = Non-Detect

Analytical results continued on the next page...



Analytical Results: Lead in Drinking Water

Item	Sample ID.	Location	Result (µ/L)
33	BLC-FRR-F	Staff Restroom, Sink Faucet	0.893
34	BLC-B-M-1	Boys Restroom, Middle, Sink Faucet #1	1.48
35	BLC-M-2	Boys Restroom, Middle, Sink Faucet #2	1.48
36	BLC-B-N1-F1	Boys Restroom, North #1, Sink Faucet #1	0.932
37	BLC-B-N1-F1	Boys Restroom, North #1, Sink Faucet #2	9.84
38	BLC-B-N2-F1	Boys Restroom, North #2, Sink Faucet #1	4.93
39	BLC-B-N2-F1	Boys Restroom, North #2, Sink Faucet #2	1.25
40	BLC-G-N-F1	Girls Restroom, North, Sink Faucet #1	1.72
41	BLC-G-N-F2	Girls Restroom, North, Sink Faucet #2	2.02
42	BLC-G-NW-F1	Girls Restroom, Northwest, Sink Faucet #1	0.784
43	BLC-G-NW-F2	Girls Restroom, Northwest, Sink Faucet #2	2.26
44	BLC-W-F2	Girls Restroom, West, Sink Faucet #2	1.03

ND = Non-Detect

As highlighted () in the above table, the lab results for 3 of the 44 drinking water samples collected were found to be at or above the 15 ppb action level for lead in drinking water. The remaining 41 drinking water samples were found to be below the 15 ppb action level.

Note: Drinking water sources with lead levels above an approximate background level of 2.0 ppb have also been highlighted ().

Conclusions and Recommendations

Three locations were noted to have elevated lead in drinking water; the drinking fountain in classroom #12, the sink faucet in classroom #14, and the sink faucet in the restroom in classroom #19. No elevated lead in drinking water levels were noted in the other locations sampled, and the results were below the lead-in-drinking water EPA standard under the Safe Drinking Water Act of 15 parts per billion. Nineteen drinking water locations did have residual lead levels above a background lead level: 2.0 ppb.

It is our recommendation that the Longview School District consider the installation of a combination drinking fountain and motion sensor water filling system using an ANSI 53 certified filter by the National Science Foundation (NSF). The Elkay EZH20 is a popular fixture and is advertised online for about \$1,500 per unit. Note that fixtures with refrigeration jump in price to around \$4,000. These systems have proven effective for the removal of lead particulates with our other school district clients.

Given the age of the Broadway Learning Center plumbing systems (built in 1947, additions/renovations in 1948, 1950, and 1976) and the slight residual levels of lead noted in the drinking water sources throughout, Sterling recommends that the district consider replacement of all the water fountains at the property with fixtures that include a suitable lead filtration system. As the existing drinking water fountains do not have an electrical source, a mechanical system would be preferable. With the mechanical fixtures, required filter changes are noted on a counter that is based on the volume of water passed through the filter.



The district might also consider instituting an administrative policy that only those drinking water sources that include a lead filtration system be used for drinking water; discourage use of unfiltered water sources (e.g., classroom sink water faucets).

Limitations

This report is for the exclusive use of the client, applies only to the specific subject property detailed above, and shall not be relied upon by any other party without the prior written consent of the undersigned.

Within the limitations of scope, schedule, and budget, our services have been executed in accordance with generally accepted practices in this area at the time this report was prepared. No other hazardous materials/wastes were investigated. No other conditions, expressed or implied, should be understood.

Recordkeeping

Additional copies of this report are available from Sterling Technologies upon request. Unless otherwise requested, samples will be retained for a period of 30 days, after which they will be discarded. If you have any questions about these results or would like additional information, please feel free to call our office.

Sterling Technologies thanks you for this opportunity to be of service.

Sincerely,



Thomas Nadermann, M.S., Principal
AHERA Inspector #155212, Lead Risk Assessor #0493



Appendix A

Inspector's Certification

DRAFT



STATE OF WASHINGTON

Department of Commerce
Lead-Based Paint Abatement Program

Thomas Heinrich Nadermann

*Has fulfilled the certification requirements of
WAC 365-230
and has been certified to conduct lead-based
paint activities as a
Risk Assessor*

<u>Certification #</u>	<u>Issuance Date</u>	<u>Expiration Date</u>
0493	02/08/2021	10/22/2023

STATE OF WASHINGTON

Department of Commerce
Lead-Based Paint Abatement Program

Edwin L Wilson

*Has fulfilled the certification requirements of
WAC 365-230
and has been certified to conduct lead-based
paint activities as a
Risk Assessor*

<u>Certification #</u>	<u>Issuance Date</u>	<u>Expiration Date</u>
8040	08/26/2021	07/22/2024



Appendix B

Field Data

Laboratory Results

DRAFT



A2B0787Apex Labs Cooler Receipt Summary ReportSterling Technologies LLC (Thomas Nadermann)

Project: Drinking Water - 2022

Project #: Broadway Learning Center

Received: 02/23/22 11:22

A2B0787

Apex PM: Darrell Auvil (DAuvil@apex-labs.com) (Phone: 503-718-2323)

One Cooler received at 11.4 deg C: (Temperature OK)

Samples:

A2B0787-01	Drinking Water	<u>BLC-3-F</u>	02/21/22 00:00
------------	----------------	----------------	----------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-02	Drinking Water	<u>BLC-4-F</u>	02/21/22 00:00
------------	----------------	----------------	----------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-03	Drinking Water	<u>BLC-5-F</u>	02/21/22 00:00
------------	----------------	----------------	----------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-04	Drinking Water	<u>BLC-5-WF</u>	02/21/22 00:00
------------	----------------	-----------------	----------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-05	Drinking Water	<u>BLC-6-F</u>	02/21/22 00:00
------------	----------------	----------------	----------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-06	Drinking Water	<u>BLC-7-F</u>	02/21/22 00:00
------------	----------------	----------------	----------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-07	Drinking Water	<u>BLC-8-F</u>	02/21/22 00:00
------------	----------------	----------------	----------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

Apex Labs Cooler Receipt Summary Report

Sterling Technologies LLC (Thomas Nadermann)						
Project: Drinking Water - 2022						
Project #: Broadway Learning Center						
Received: 02/23/22 11:22						A2B0787
A2B0787-08	Drinking Water	<u>BLC-10-RR-F1</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-09	Drinking Water	<u>BLC-10-RR-F2</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-10	Drinking Water	<u>BLC-11-F</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-11	Drinking Water	<u>BLC-12-F</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-12	Drinking Water	<u>BLC-12-WF</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-13	Drinking Water	<u>BLC-13-F</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-14	Drinking Water	<u>BLC-14-F</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-15	Drinking Water	<u>BLC-15-F</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-16	Drinking Water	<u>BLC-16-F</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-17	Drinking Water	<u>BLC-18-F1</u>				02/21/22 00:00
<u>Analysis</u>		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

Apex Labs Cooler Receipt Summary Report

Sterling Technologies LLC (Thomas Nadermann)

Project: Drinking Water - 2022

Project #: Broadway Learning Center

Received: 02/23/22 11:22

A2B0787

A2B0787-18		Drinking Water		BLC-18-F2		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-19		Drinking Water		BLC-18-F3		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-20		Drinking Water		BLC-19-F1		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-21		Drinking Water		BLC-19-F2		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-22		Drinking Water		BLC-19-F3		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-23		Drinking Water		BLC-19-RR-F1		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-24		Drinking Water		BLC-19-RR-F2		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-25		Drinking Water		BLC-20-F		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-26		Drinking Water		BLC-C-F		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	
A2B0787-27		Drinking Water		BLC-N-F		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	

Apex Labs Cooler Receipt Summary Report

Sterling Technologies LLC (Thomas Nadermann)

Project: Drinking Water - 2022

Project #: Broadway Learning Center

Received: 02/23/22 11:22

A2B0787

A2B0787-28		Drinking Water	BLC-K-F1		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-29		Drinking Water	BLC-K-F2		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-30		Drinking Water	BLC-K-F3		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-31		Drinking Water	BLC-ST-L-F		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-32		Drinking Water	BLC-SRR-F		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-33		Drinking Water	BLC-FRR-F		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-34		Drinking Water	BLC-B-M-1		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-35		Drinking Water	BLC-B-M-2		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-36		Drinking Water	BLC-B-N1-F1		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022
A2B0787-37		Drinking Water	BLC-B-N1-F2		02/21/22 00:00	
Analysis		TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total		10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

Apex Labs Cooler Receipt Summary Report

Sterling Technologies LLC (Thomas Nadermann)

Project: Drinking Water - 2022

Project #: Broadway Learning Center

Received: 02/23/22 11:22

A2B0787

A2B0787-38	Drinking Water	<u>BLC-B-N2-F1</u>	02/21/22 00:00
-------------------	-----------------------	---------------------------	-----------------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-39	Drinking Water	<u>BLC-B-N2-F2</u>	02/21/22 00:00
-------------------	-----------------------	---------------------------	-----------------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-40	Drinking Water	<u>BLC-G-N-F1</u>	02/21/22 00:00
-------------------	-----------------------	--------------------------	-----------------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-41	Drinking Water	<u>BLC-G-N-F2</u>	02/21/22 00:00
-------------------	-----------------------	--------------------------	-----------------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-42	Drinking Water	<u>BLC-G-NW-F1</u>	02/21/22 00:00
-------------------	-----------------------	---------------------------	-----------------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

A2B0787-43	Drinking Water	<u>BLC-G-NW-F2</u>	02/21/22 00:00
-------------------	-----------------------	---------------------------	-----------------------

Analysis	TAT	Due	Hold1	Hold1 Type	Expires
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022

Apex Labs Cooler Receipt Summary Report

A2B0787-44	Drinking Water	BLC-G-W-F2	02/21/22 00:00			
Analysis	TAT	Due	Hold1	Hold1 Type	Expires	
Pb (Lead) - 200.8 - Total	10	3/9/2022	180	Sampled to Analyzed (Day)	8/20/2022	

Chain of Custody

Field Sampling Log

Sterling Technologies, LLC

Providing technical consulting support to the
environmental and manufacturing industries

317 NE 144th Street Vancouver, WA 98685
360.576.6331

Pg 1 of 4

Project Name: Test Drinking Water for Lead
Site Location: Broadway Learning Center
Date: Feb 21, 2022
Project Contact: T. Nadlermann

Turnaround Time:

Normal: X

Other: _____

Sample ID	Location/Description	Analysis	Comments
BLC-3-F	Class Rm - 3 - Sink Faucet	Lead	EPA Method 200.8
" - 4 - F	" - 4 - "		
" - 5 - F	" - 5 - "		
" - 5 - WF	" - 5 - Water Fountain		
" - 6 - F	" - 6 - Sink Faucet		
" - 7 - F	" - 7 - "		
" - 8 - F	" - 8 - "		
" - 10 - RR-F1	" - 10 - Rest - Sink - #1		
" - 10 - " - F2	" - 10 - " - " - #2		
" - 11 - F	" - 11 - Sink Faucet		
" - 12 - F	" - 12 - "		
" - 12 - WF	" - 12 - Water Fountain		
" - 13 - F	" - 13 - Sink Faucet		

Sampled by:

T. Nadlermann
E. Wilson

Date:

Feb 21, 2022

1/22

M. Kadish / Michael Kadish 2-23-22

Chain of Custody

Field Sampling Log

Sterling Technologies, LLC
 Providing technical consulting support to the
 environmental and manufacturing industries

317 NE 144th Street Vancouver, WA 98685
 360.576.6331

A2B0787

Project Name:

Site Location:

Date:

Project Contact:

Test Drinking Water for Lead

Broadway Learning Center

Feb 21, 2022

T. Naeckermann

Turnaround Time:

Normal:

Other:

Pg 2 of 4

Sample ID	Location/Description	Analysis	Comments
BLC-14-F	Glass - 14 - Sink Faucet	Lead	EPA Method 200.8
BLC-15-F	" - 15 - "		
BLC-16-F	" - 16 - "		
BLC-18-F1	" - 18 - Sink Faucet #1		
" - " - F2	" - 18 - " - #2		
" - " - F3	" - 18 - " - #3		
BLC-19-F1	" - 19 - " - #1		
" - " - F2	" - 19 - " - #2		
" - " - F3	" - 19 - " - #3		
" - " - RR-F1	" - " - Rest - Sink Faucet - #1		
" - " - " - F2	" - " - " - " - #2		
BLC-20-F	" - 20 - Sink Faucet		
BLC-C-F	Custodial " "		

Sampled by:

T. Naeckermann
E. Wilson

Date:

Feb 21, 2022

1122

M. Kachuk

2-23-22

Chain of Custody

Field Sampling Log

A2B0787

Sterling Technologies, LLC

Providing technical consulting support to the
environmental and manufacturing industries317 NE 144th Street Vancouver, WA 98685
360.576.6331

Pg 3 of 4

Test Drinking Water for Lead
 Broadway Learning Center
 Feb 21, 2022
 T. Nadermann

Project Name:

Site Location:

Date:

Project Contact:

Turnaround Time:

Normal: ☒

Other:

Sample ID	Location/Description	Analysis	Comments
BLC-N-F	Health Office - Sink Faucet	Lead	EPA Method 200.8
" - K - F1	Kitchen - Sink Faucet - #1		
" - " - F2	" - " - #2		
" - " - F3	" - " - #3		
" - ST-L-F	Staff Lounge - Sink Faucet		
" - SRR-F	Staff Rest Rm - "		
" - FRR-F	Faculty Rest Rm - "		
" - B-M-1	Box Rm - Middle Sink - #1		
" - B-M-2	" - " - " - #2		
" - B-N1-F1	" - North #1 - " - #1		
" - B-N1-F2	" - " - " - " - #2		
" - B-N2-F1	" - North #2 - " - #1		
" - B-N2-F2	" - " - " - " - #2		

Sampled by:

T. Nadermann
E. Wilson

Date: Feb 21, 2022

1172
 2-23-22
 M. Kachnik

Field Sampling Log



Sterling Technologies, LLC

Providing technical consulting support to the environmental and manufacturing industries

317 NE 144th Street Vancouver, WA 98685
360.576.6331

Handwritten text: I go to A

Test Drinking Water for Lead

Broadway Learning Center

Feb 21, 2022

T. Wackermann

Project Name:

Site Location:

Date:

Project Contact:

Turnaround Time:

Normal:

Other:

[illegible]

Sampled by:

T. Nachermann
E. Wilson

Date: Feb 21, 2022

1172
223-22

Apex Labs Cooler Receipt Summary Report

APEX LABS COOLER RECEIPT FORM

Client: Starling Technologies LLC Element WO#: A2 B0787

Project/Project #: Test Drinking Water for Lead- Broadway Learning Center

Delivery Info:

Date/time received: 2-23-22 @ 1122 By: MM

Delivered by: Apex ☒ Client ☐ ESS ☐ FedEx ☐ UPS ☐ Swift ☐ Senvoy ☐ SDS ☐ Other ☐

Cooler Inspection Date/time inspected: 2-23-22 @ 1250 By: MM

Chain of Custody included? Yes ☒ No ☐ Custody seals? Yes ☐ No ☒

Signed/dated by client? Yes ☒ No ☐

Signed/dated by Apex? Yes ☒ No ☐

	Cooler #1	Cooler #2	Cooler #3	Cooler #4	Cooler #5	Cooler #6	Cooler #7
Temperature (°C)	<u>11.4</u>						
Received on ice? (Y/N)	<u>N</u>						
Temp. blanks? (Y/N)	<u>N</u>						
Ice type: (Gel/Real/Other)	<u>N/A</u>						
Condition:	<u>good</u>						

Cooler out of temp? (Y/N) Possible reason why: Drinking Water/Lead Testing

Green dots applied to out of temperature samples? Yes ☒ No ☐

Out of temperature samples form initiated? Yes ☒ No ☐

Sample Inspection: Date/time inspected: 2/25/22 @ 12:08 By: ZAM

All samples intact? Yes ☒ No ☐ Comments: KAM 2/25/22

Bottle labels/COCs agree? Yes ☐ No ☒ Comments: Container 250m BLC-20-FR 2AM 2/25/22
reads BLC-21-F.

COC/container discrepancies form initiated? Yes ☐ No ☒

Containers/volumes received appropriate for analysis? Yes ☒ No ☐ Comments: 2AM 2/25/22

Do VOA vials have visible headspace? Yes ☐ No ☐ NA ☒

Comments: 2AM 2/25/22

Water samples: pH checked: Yes ☒ No ☐ NA ☒ pH appropriate? Yes ☒ No ☐ NA ☒

Comments: 2AM 2/25/22

Additional information:

Labeled by:

ZAM

Witness:

AKK

Cooler Inspected by:

ZAM



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Monday, March 14, 2022

Thomas Nadermann
Sterling Technologies LLC
317 NE 144th St
Vancouver, WA 98685

RE: A2B0787 - Drinking Water - 2022 - Broadway Learning Center

Thank you for using Apex Laboratories. We greatly appreciate your business and strive to provide the highest quality services to the environmental industry.

Enclosed are the results of analyses for work order A2B0787, which was received by the laboratory on 2/23/2022 at 11:22:00AM.

If you have any questions concerning this report or the services we offer, please feel free to contact me by email at: DAuvil@apex-labs.com, or by phone at 503-718-2323.

Please note: All samples will be disposed of within 30 days of sample receipt, unless prior arrangements have been made.

Cooler Receipt Information

(See Cooler Receipt Form for details)

Cooler #1	11.4 degC
-----------	-----------

This Final Report is the official version of the data results for this sample submission, unless superseded by a subsequent, labeled amended report.

All other deliverables derived from this data, including Electronic Data Deliverables (EDDs), CLP-like forms, client requested summary sheets, and all other products are considered secondary to this report.



Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062Sterling Technologies LLC317 NE 144th St
Vancouver, WA 98685Project: Drinking Water - 2022Project Number: Broadway Learning Center
Project Manager: Thomas NadermannReport ID:

A2B0787 - 03 14 22 0946

ANALYTICAL REPORT FOR SAMPLES

SAMPLE INFORMATION

Client Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
BLC-3-F	A2B0787-01	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-4-F	A2B0787-02	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-5-F	A2B0787-03	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-5-WF	A2B0787-04	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-6-F	A2B0787-05	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-7-F	A2B0787-06	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-8-F	A2B0787-07	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-10-RR-F1	A2B0787-08	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-10-RR-F2	A2B0787-09	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-11-F	A2B0787-10	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-12-F	A2B0787-11	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-12-WF	A2B0787-12	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-13-F	A2B0787-13	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-14-F	A2B0787-14	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-15-F	A2B0787-15	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-16-F	A2B0787-16	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-18-F1	A2B0787-17	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-18-F2	A2B0787-18	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-18-F3	A2B0787-19	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-19-F1	A2B0787-20	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-19-F2	A2B0787-21	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-19-F3	A2B0787-22	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-19-RR-F1	A2B0787-23	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-19-RR-F2	A2B0787-24	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-20-F	A2B0787-25	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-C-F	A2B0787-26	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-N-F	A2B0787-27	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-K-F1	A2B0787-28	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-K-F2	A2B0787-29	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-K-F3	A2B0787-30	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-ST-L-F	A2B0787-31	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-SRR-F	A2B0787-32	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-FRR-F	A2B0787-33	Drinking Water	02/21/22 00:00	02/23/22 11:22

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager

Page 2 of 22

**ANALYTICAL REPORT****Apex Laboratories, LLC**6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062**Sterling Technologies LLC**317 NE 144th St
Vancouver, WA 98685Project: **Drinking Water - 2022**Project Number: **Broadway Learning Center**Project Manager: **Thomas Nadermann****Report ID:****A2B0787 - 03 14 22 0946****ANALYTICAL REPORT FOR SAMPLES****SAMPLE INFORMATION**

Client Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
BLC-B-M-1	A2B0787-34	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-B-M-2	A2B0787-35	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-B-N1-F1	A2B0787-36	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-B-N1-F2	A2B0787-37	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-B-N2-F1	A2B0787-38	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-B-N2-F2	A2B0787-39	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-G-N-F1	A2B0787-40	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-G-N-F2	A2B0787-41	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-G-NW-F1	A2B0787-42	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-G-NW-F2	A2B0787-43	Drinking Water	02/21/22 00:00	02/23/22 11:22
BLC-G-W-F2	A2B0787-44	Drinking Water	02/21/22 00:00	02/23/22 11:22

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062Sterling Technologies LLC317 NE 144th St
Vancouver, WA 98685Project: Drinking Water - 2022Project Number: **Broadway Learning Center**
Project Manager: **Thomas Nadermann**Report ID:

A2B0787 - 03 14 22 0946

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
BLC-3-F (A2B0787-01) Matrix: Drinking Water								
Batch: 22B0984								
Lead	0.554	---	0.200	ug/L	1	03/02/22 15:19	EPA 200.8	
BLC-4-F (A2B0787-02) Matrix: Drinking Water								
Batch: 22B0984								
Lead	0.496	---	0.200	ug/L	1	03/02/22 15:38	EPA 200.8	
BLC-5-F (A2B0787-03) Matrix: Drinking Water								
Batch: 22B0984								
Lead	0.689	---	0.200	ug/L	1	03/02/22 15:41	EPA 200.8	
BLC-5-WF (A2B0787-04) Matrix: Drinking Water								
Batch: 22B0984								
Lead	4.06	---	0.200	ug/L	1	03/02/22 15:44	EPA 200.8	
BLC-6-F (A2B0787-05) Matrix: Drinking Water								
Batch: 22B0984								
Lead	ND	---	0.200	ug/L	1	03/02/22 15:48	EPA 200.8	
BLC-7-F (A2B0787-06) Matrix: Drinking Water								
Batch: 22B0984								
Lead	1.41	---	0.200	ug/L	1	03/02/22 15:52	EPA 200.8	
BLC-8-F (A2B0787-07) Matrix: Drinking Water								
Batch: 22B0984								
Lead	1.66	---	0.200	ug/L	1	03/02/22 15:56	EPA 200.8	
BLC-10-RR-F1 (A2B0787-08) Matrix: Drinking Water								
Batch: 22B0984								
Lead	6.71	---	0.200	ug/L	1	03/02/22 16:00	EPA 200.8	
BLC-10-RR-F2 (A2B0787-09) Matrix: Drinking Water								
Batch: 22B0984								
Lead	2.77	---	0.200	ug/L	1	03/02/22 16:04	EPA 200.8	
BLC-11-F (A2B0787-10) Matrix: Drinking Water								
Batch: 22B0984								

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685Project: Drinking Water - 2022Project Number: **Broadway Learning Center**
Project Manager: **Thomas Nadermann****Report ID:****A2B0787 - 03 14 22 0946**

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
BLC-11-F (A2B0787-10)				Matrix: Drinking Water				
Lead	9.02	---	0.200	ug/L	1	03/02/22 16:19	EPA 200.8	
BLC-12-F (A2B0787-11RE1)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	115	---	2.00	ug/L	10	03/02/22 17:18	EPA 200.8	
BLC-12-WF (A2B0787-12RE1)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	93.2	---	2.00	ug/L	10	03/02/22 17:22	EPA 200.8	
BLC-13-F (A2B0787-13)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	0.277	---	0.200	ug/L	1	03/02/22 16:32	EPA 200.8	
BLC-14-F (A2B0787-14)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	17.6	---	0.200	ug/L	1	03/02/22 16:35	EPA 200.8	
BLC-15-F (A2B0787-15)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	1.23	---	0.200	ug/L	1	03/02/22 16:39	EPA 200.8	
BLC-16-F (A2B0787-16)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	0.768	---	0.200	ug/L	1	03/02/22 16:43	EPA 200.8	
BLC-18-F1 (A2B0787-17)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	4.47	---	0.200	ug/L	1	03/02/22 16:46	EPA 200.8	
BLC-18-F2 (A2B0787-18)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	3.56	---	0.200	ug/L	1	03/02/22 16:50	EPA 200.8	
BLC-18-F3 (A2B0787-19)				Matrix: Drinking Water				
Batch: 22B0984								

Apex Laboratories

Darrell Auvil, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685

Project: Drinking Water - 2022

Project Number: **Broadway Learning Center**
Project Manager: **Thomas Nadermann**

Report ID:

A2B0787 - 03 14 22 0946

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
BLC-18-F3 (A2B0787-19)				Matrix: Drinking Water				
Lead	14.7	---	0.200	ug/L	1	03/02/22 16:54	EPA 200.8	
BLC-19-F1 (A2B0787-20)				Matrix: Drinking Water				
Batch: 22B0984								
Lead	13.9	---	0.200	ug/L	1	03/02/22 17:10	EPA 200.8	
BLC-19-F2 (A2B0787-21)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	2.29	---	0.200	ug/L	1	03/02/22 17:34	EPA 200.8	
BLC-19-F3 (A2B0787-22)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	12.1	---	0.200	ug/L	1	03/02/22 17:46	EPA 200.8	
BLC-19-RR-F1 (A2B0787-23)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	9.17	---	0.200	ug/L	1	03/02/22 17:58	EPA 200.8	
BLC-19-RR-F2 (A2B0787-24)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	17.7	---	0.200	ug/L	1	03/02/22 18:02	EPA 200.8	
BLC-20-F (A2B0787-25)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	3.83	---	0.200	ug/L	1	03/02/22 18:06	EPA 200.8	
BLC-C-F (A2B0787-26)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	0.470	---	0.200	ug/L	1	03/02/22 18:10	EPA 200.8	
BLC-N-F (A2B0787-27)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	5.38	---	0.200	ug/L	1	03/02/22 18:13	EPA 200.8	
BLC-K-F1 (A2B0787-28)				Matrix: Drinking Water				
Batch: 22B0986								

Apex Laboratories

Darrell Auvil, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685Project: Drinking Water - 2022Project Number: **Broadway Learning Center**Project Manager: **Thomas Nadermann****Report ID:****A2B0787 - 03 14 22 0946**

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
BLC-K-F1 (A2B0787-28)				Matrix: Drinking Water				
Lead	0.521	---	0.200	ug/L	1	03/02/22 18:17	EPA 200.8	
BLC-K-F2 (A2B0787-29)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	3.65	---	0.200	ug/L	1	03/02/22 18:21	EPA 200.8	
BLC-K-F3 (A2B0787-30)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	4.90	---	0.200	ug/L	1	03/02/22 18:25	EPA 200.8	
BLC-ST-L-F (A2B0787-31)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	0.408	---	0.200	ug/L	1	03/02/22 18:29	EPA 200.8	
BLC-SRR-F (A2B0787-32)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	1.11	---	0.200	ug/L	1	03/02/22 18:32	EPA 200.8	
BLC-FRR-F (A2B0787-33)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	0.893	---	0.200	ug/L	1	03/02/22 18:44	EPA 200.8	
BLC-B-M-1 (A2B0787-34)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	1.48	---	0.200	ug/L	1	03/02/22 18:47	EPA 200.8	
BLC-B-M-2 (A2B0787-35)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	1.48	---	0.200	ug/L	1	03/02/22 18:51	EPA 200.8	
BLC-B-N1-F1 (A2B0787-36RE1)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	0.932	---	0.200	ug/L	1	03/02/22 19:06	EPA 200.8	
BLC-B-N1-F2 (A2B0787-37)				Matrix: Drinking Water				
Batch: 22B0986								

Apex Laboratories

Darrell Auvil, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323

ORELAP ID: OR100062

Sterling Technologies LLC317 NE 144th St
Vancouver, WA 98685Project: Drinking Water - 2022Project Number: **Broadway Learning Center**Project Manager: **Thomas Nadermann**Report ID:

A2B0787 - 03 14 22 0946

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
BLC-B-N1-F2 (A2B0787-37)				Matrix: Drinking Water				
Lead	9.84	---	0.200	ug/L	1	03/02/22 18:58	EPA 200.8	
BLC-B-N2-F1 (A2B0787-38)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	4.93	---	0.200	ug/L	1	03/02/22 19:02	EPA 200.8	
BLC-B-N2-F2 (A2B0787-39)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	1.25	---	0.200	ug/L	1	03/02/22 19:10	EPA 200.8	
BLC-G-N-F1 (A2B0787-40)				Matrix: Drinking Water				
Batch: 22B0986								
Lead	1.72	---	0.200	ug/L	1	03/02/22 19:14	EPA 200.8	
BLC-G-N-F2 (A2B0787-41)				Matrix: Drinking Water				
Batch: 22B1008								
Lead	2.02	---	0.200	ug/L	1	03/02/22 19:37	EPA 200.8	
BLC-G-NW-F1 (A2B0787-42)				Matrix: Drinking Water				
Batch: 22B1008								
Lead	0.784	---	0.200	ug/L	1	03/02/22 19:49	EPA 200.8	
BLC-G-NW-F2 (A2B0787-43)				Matrix: Drinking Water				
Batch: 22B1008								
Lead	2.26	---	0.200	ug/L	1	03/02/22 19:53	EPA 200.8	
BLC-G-W-F2 (A2B0787-44)				Matrix: Drinking Water				
Batch: 22B1008								
Lead	1.03	---	0.200	ug/L	1	03/02/22 19:57	EPA 200.8	

Apex Laboratories

Darrell Auvil, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St

Vancouver, WA 98685

Project: Drinking Water - 2022Project Number: **Broadway Learning Center**Project Manager: **Thomas Nadermann****Report ID:****A2B0787 - 03 14 22 0946**

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	Detection Limit	Reporting Limit	Units	Dilution	Spike Amount	Source Result	% REC	% REC Limits	RPD	RPD Limit	Notes
Batch 22B0984 - EPA 200.8 Direct Analysis						Drinking Water						
Blank (22B0984-BLK1)			Prepared: 02/28/22 10:20		Analyzed: 03/02/22 15:12							
<u>EPA 200.8</u>												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	
LCS (22B0984-BS1)			Prepared: 02/28/22 10:20		Analyzed: 03/02/22 15:15							
<u>EPA 200.8</u>												
Lead	16.0	---	0.201	ug/L	1	15.0	---	107	85-115%	---	---	
Duplicate (22B0984-DUP1)			Prepared: 02/28/22 10:20		Analyzed: 03/02/22 15:30							
<u>QC Source Sample: BLC-3-F (A2B0787-01)</u>												
<u>EPA 200.8</u>												
Lead	0.526	---	0.200	ug/L	1	---	0.554	---	---	5	20%	
Matrix Spike (22B0984-MS1)			Prepared: 02/28/22 10:20		Analyzed: 03/02/22 15:34							
<u>QC Source Sample: BLC-3-F (A2B0787-01)</u>												
<u>EPA 200.8</u>												
Lead	15.4	---	0.201	ug/L	1	15.0	0.554	99	70-130%	---	---	
Matrix Spike (22B0984-MS2)			Prepared: 02/28/22 10:20		Analyzed: 03/02/22 17:14							
<u>QC Source Sample: BLC-19-F1 (A2B0787-20)</u>												
<u>EPA 200.8</u>												
Lead	28.6	---	0.201	ug/L	1	15.0	13.9	98	70-130%	---	---	
Batch 22B0986 - EPA 200.8 Direct Analysis						Drinking Water						
Blank (22B0986-BLK1)			Prepared: 02/28/22 10:26		Analyzed: 03/02/22 17:26							
<u>EPA 200.8</u>												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	
LCS (22B0986-BS1)			Prepared: 02/28/22 10:26		Analyzed: 03/02/22 17:30							
<u>EPA 200.8</u>												
Lead	15.6	---	0.201	ug/L	1	15.0	---	104	85-115%	---	---	
Duplicate (22B0986-DUP1)			Prepared: 02/28/22 10:26		Analyzed: 03/02/22 17:38							

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St

Vancouver, WA 98685

Project: Drinking Water - 2022Project Number: **Broadway Learning Center**Project Manager: **Thomas Nadermann****Report ID:****A2B0787 - 03 14 22 0946**

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	Detection Limit	Reporting Limit	Units	Dilution	Spike Amount	Source Result	% REC	% REC Limits	RPD	RPD Limit	Notes
Batch 22B0986 - EPA 200.8 Direct Analysis							Drinking Water					
Duplicate (22B0986-DUP1)			Prepared: 02/28/22 10:26 Analyzed: 03/02/22 17:38									
QC Source Sample: BLC-19-F2 (A2B0787-21)												
EPA 200.8												
Lead	2.26	---	0.200	ug/L	1	---	2.29	---	---	2	20%	
Matrix Spike (22B0986-MS1)			Prepared: 02/28/22 10:26 Analyzed: 03/02/22 17:42									
QC Source Sample: BLC-19-F2 (A2B0787-21)												
EPA 200.8												
Lead	17.2	---	0.201	ug/L	1	15.0	2.29	100	70-130%	---	---	
Matrix Spike (22B0986-MS2)			Prepared: 02/28/22 10:26 Analyzed: 03/02/22 19:18									
QC Source Sample: BLC-G-N-F1 (A2B0787-40)												
EPA 200.8												
Lead	16.7	---	0.201	ug/L	1	15.0	1.72	100	70-130%	---	---	

Apex Laboratories

Darrell Auvil, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685Project: Drinking Water - 2022

Project Number: Broadway Learning Center

Project Manager: Thomas Nadermann

Report ID:

A2B0787 - 03 14 22 0946

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	Detection Limit	Reporting Limit	Units	Dilution	Spike Amount	Source Result	% REC	% REC Limits	RPD	RPD Limit	Notes
Batch 22B1008 - EPA 200.8 Direct Analysis						Drinking Water						
Blank (22B1008-BLK1)			Prepared: 02/28/22 15:29		Analyzed: 03/02/22 19:30							
EPA 200.8												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	
LCS (22B1008-BS1)			Prepared: 02/28/22 15:29		Analyzed: 03/02/22 19:33							
EPA 200.8												
Lead	15.3	---	0.201	ug/L	1	15.0	---	102	85-115%	---	---	
Duplicate (22B1008-DUP1)			Prepared: 02/28/22 15:29		Analyzed: 03/02/22 19:41							
QC Source Sample: BLC-G-N-F2 (A2B0787-41)												
EPA 200.8												
Lead	2.04	---	0.200	ug/L	1	---	2.02	---	---	0.9	20%	
Matrix Spike (22B1008-MS1)			Prepared: 02/28/22 15:29		Analyzed: 03/02/22 19:45							
QC Source Sample: BLC-G-N-F2 (A2B0787-41)												
EPA 200.8												
Lead	17.0	---	0.201	ug/L	1	15.0	2.02	100	70-130%	---	---	
Matrix Spike (22B1008-MS2)			Prepared: 02/28/22 15:29		Analyzed: 03/02/22 21:09							
QC Source Sample: Non-SDG (A2B0851-16)												
EPA 200.8												
Lead	14.8	---	0.201	ug/L	1	15.0	0.101	98	70-130%	---	---	

Apex Laboratories

Darrell Auvil, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

**ANALYTICAL REPORT****Apex Laboratories, LLC**6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323

ORELAP ID: OR100062

Sterling Technologies LLC317 NE 144th St
Vancouver, WA 98685Project: **Drinking Water - 2022**Project Number: **Broadway Learning Center**Project Manager: **Thomas Nadermann****Report ID:****A2B0787 - 03 14 22 0946****SAMPLE PREPARATION INFORMATION****Total Metals in Drinking Water by EPA 200.8 (ICPMS)****Prep: EPA 200.8 Direct Analysis**

Lab Number	Matrix	Method	Sampled	Prepared	Sample Initial/Final	Default Initial/Final	RL Prep Factor
Batch: 22B0984							
A2B0787-01	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-02	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-03	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-04	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-05	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-06	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-07	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-08	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-09	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-10	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-11RE1	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-12RE1	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-13	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-14	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-15	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-16	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-17	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-18	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-19	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
A2B0787-20	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:20	10mL/10mL	10mL/10mL	1.00
Batch: 22B0986							
A2B0787-21	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-22	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-23	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-24	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-25	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-26	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-27	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-28	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-29	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-30	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-31	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-32	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-33	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-34	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-35	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685

Project: **Drinking Water - 2022**

Project Number: **Broadway Learning Center**
Project Manager: **Thomas Nadermann**

Report ID:

A2B0787 - 03 14 22 0946

SAMPLE PREPARATION INFORMATION

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Prep: EPA 200.8 Direct Analysis

Lab Number	Matrix	Method	Sampled	Prepared	Sample Initial/Final	Default Initial/Final	RL Prep Factor
A2B0787-36RE1	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-37	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-38	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-39	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
A2B0787-40	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 10:26	10mL/10mL	10mL/10mL	1.00
<u>Batch: 22B1008</u>							
A2B0787-41	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 15:29	10mL/10mL	10mL/10mL	1.00
A2B0787-42	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 15:29	10mL/10mL	10mL/10mL	1.00
A2B0787-43	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 15:29	10mL/10mL	10mL/10mL	1.00
A2B0787-44	Drinking Water	EPA 200.8	02/21/22 00:00	02/28/22 15:29	10mL/10mL	10mL/10mL	1.00

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685

Project: Drinking Water - 2022

Project Number: **Broadway Learning Center**
Project Manager: **Thomas Nadermann**

Report ID:

A2B0787 - 03 14 22 0946

QUALIFIER DEFINITIONS

Client Sample and Quality Control (QC) Sample Qualifier Definitions:

There are No Qualifiers on Sample or QC Data for this report

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685

Project: **Drinking Water - 2022**

Project Number: **Broadway Learning Center**

Project Manager: **Thomas Nadermann**

Report ID:

A2B0787 - 03 14 22 0946

REPORTING NOTES AND CONVENTIONS:

Abbreviations:

DET Analyte DETECTED at or above the detection or reporting limit.
ND Analyte NOT DETECTED at or above the detection or reporting limit.
NR Result Not Reported
RPD Relative Percent Difference. RPDs for Matrix Spikes and Matrix Spike Duplicates are based on concentration, not recovery.

Detection Limits: Limit of Detection (LOD)

Limits of Detection (LODs) are normally set at a level of one half the validated Limit of Quantitation (LOQ).
If no value is listed ('-----'), then the data has not been evaluated below the Reporting Limit.

Reporting Limits: Limit of Quantitation (LOQ)

Validated Limits of Quantitation (LOQs) are reported as the Reporting Limits for all analyses where the LOQ, MRL, PQL or CRL are requested. The LOQ represents a level at or above the low point of the calibration curve, that has been validated according to Apex Laboratories' comprehensive LOQ policies and procedures.

Reporting Conventions:

Basis: Results for soil samples are generally reported on a 100% dry weight basis.
The Result Basis is listed following the units as "dry", "wet", or " " (blank) designation.

"dry" Sample results and Reporting Limits are reported on a dry weight basis. (i.e. "ug/kg dry")
See Percent Solids section for details of dry weight analysis.
"wet" Sample results and Reporting Limits for this analysis are normally dry weight corrected, but have not been modified in this case.
" " Results without 'wet' or 'dry' designation are not normally dry weight corrected. These results are considered 'As Received'.

QC Source:

In cases where there is insufficient sample provided for Sample Duplicates and/or Matrix Spikes, a Lab Control Sample Duplicate (LCS Dup) may be analyzed to demonstrate accuracy and precision of the extraction batch.

Non-Client Batch QC Samples (Duplicates and Matrix Spike/Duplicates) may not be included in this report. Please request a Full QC report if this data is required.

Miscellaneous Notes:

" --- " QC results are not applicable. For example, % Recoveries for Blanks and Duplicates, % RPD for Blanks, Blank Spikes and Matrix Spikes, etc.

" *** " Used to indicate a possible discrepancy with the Sample and Sample Duplicate results when the %RPD is not available. In this case, either the Sample or the Sample Duplicate has a reportable result for this analyte, while the other is Non Detect (ND).

Blanks:

Standard practice is to evaluate the results from Blank QC Samples down to a level equal to ½ the Reporting Limit (RL).
-For Blank hits falling between ½ the RL and the RL (J flagged hits), the associated sample and QC data will receive a 'B-02' qualifier.
-For Blank hits above the RL, the associated sample and QC data will receive a 'B' qualifier, per Apex Laboratories' Blank Policy.
For further details, please request a copy of this document.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685

Project: **Drinking Water - 2022**

Project Number: **Broadway Learning Center**
Project Manager: **Thomas Nadermann**

Report ID:
A2B0787 - 03 14 22 0946

REPORTING NOTES AND CONVENTIONS (Cont.):

Blanks (Cont.):

Sample results flagged with a 'B' or 'B-02' qualifier are potentially biased high if the sample results are less than ten times the level found in the blank for inorganic analyses, or less than five times the level found in the blank for organic analyses.

'B' and 'B-02' qualifications are only applied to sample results detected above the Reporting Level.

Preparation Notes:

Mixed Matrix Samples:

Water Samples:

Water samples containing significant amounts of sediment are decanted or separated prior to extraction, and only the water portion analyzed, unless otherwise directed by the client.

Soil and Sediment Samples:

Soil and Sediment samples containing significant amounts of water are decanted prior to extraction, and only the solid portion analyzed, unless otherwise directed by the client.

Sampling and Preservation Notes:

Certain regulatory programs, such as National Pollutant Discharge Elimination System (NPDES), require that activities such as sample filtration (for dissolved metals, orthophosphate, hexavalent chromium, etc.) and testing of short hold analytes (pH, Dissolved Oxygen, etc.) be performed in the field (on-site) within a short time window. In addition, sample matrix spikes are required for some analyses, and sufficient volume must be provided, and billable site specific QC requested, if this is required. All regulatory permits should be reviewed to ensure that these requirements are being met.

Data users should be aware of which regulations pertain to the samples they submit for testing. If related sample collection activities are not approved for a particular regulatory program, results should be considered estimates. Apex Laboratories will qualify these analytes according to the most stringent requirements, however results for samples that are for non-regulatory purposes may be acceptable.

Samples that have been filtered and preserved at Apex Laboratories per client request are listed in the preparation section of the report with the date and time of filtration listed.

Apex Laboratories maintains detailed records on sample receipt, including client label verification, cooler temperature, sample preservation, hold time compliance and field filtration. Data is qualified as necessary, and the lack of qualification indicates compliance with required parameters.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685

Project: **Drinking Water - 2022**

Project Number: **Broadway Learning Center**

Project Manager: **Thomas Nadermann**

Report ID:

A2B0787 - 03 14 22 0946

LABORATORY ACCREDITATION INFORMATION

ORELAP Certification ID: OR100062 (Primary Accreditation) -
EPA ID: OR01039

All methods and analytes reported from work performed at Apex Laboratories are included on Apex Laboratories' ORELAP Scope of Certification, with the exception of any analyte(s) listed below:

Apex Laboratories

Matrix	Analysis	TNI_ID	Analyte	TNI_ID	Accreditation
<u>All reported analytes are included in Apex Laboratories' current ORELAP scope.</u>					

Secondary Accreditations

Apex Laboratories also maintains reciprocal accreditation with non-TNI states (Washington DOE), as well as other state specific accreditations not listed here.

Subcontract Laboratory Accreditations

Subcontracted data falls outside of Apex Laboratories' Scope of Accreditation.

Please see the Subcontract Laboratory report for full details, or contact your Project Manager for more information.

Field Testing Parameters

Results for Field Tested data are provided by the client or sampler, and fall outside of Apex Laboratories' Scope of Accreditation.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685

Project: Drinking Water - 2022

Project Number: Broadway Learning Center

Project Manager: Thomas Nadermann

Report ID:

A2B0787 - 03 14 22 0946

Chain of Custody

Field Sampling Log

Sterling Technologies, LLC

Providing technical consulting support to the
environmental and manufacturing industries

317 NE 144th Street Vancouver, WA 98685
360.576.6331

Project Name:

Site Location:

Date:

Project Contact:

Test Drinking Water for Lead
Broadway Learning Center
Feb 21, 2022
T. Nadermann

Pg 1 of 4

Turnaround Time:

Normal: ☒

Other: ☐

Sample ID	Location/Description	Analysis	Comments
BLC-3-F	Glass - 3- Sink Faucet	Lead	EPA Method 200.8
" - 4-F	" - 4- "		
" - 5-F	" - 5- "		
" - 5-WF	" - 5- Water Fountain		
" - 6-F	" - 6- Sink Faucet		
" - 7-F	" - 7- "		
" - 8-F	" - 8- "		
" - 10-RR-F1	" - 10- Rest - Sink - #1		
" - 10-RR-F2	" - 10- " - " - #2		
" - 11-F	" - 11- Sink Faucet		
" - 12-F	" - 12- "		
" - 12-WF	" - 12- Water Fountain		
" - 13-F	" - 13- Sink Faucet		

Sampled by:

T. Nadermann
E. Wilson

Date:

Feb 21, 2022
1122
M. Nadermann / Michael Kaufman 2-23-22

Sterling Technologies LLC

317 NE 144th St

Vancouver, WA 98685

Project: Drinking Water - 2022

Project Number: Broadway Learning Center

Project Manager: Thomas Nadermann

Report ID:

A2B0787 - 03 14 22 0946

Chain of Custody

Field Sampling Log

Sterling Technologies, LLC

Providing technical consulting support to the
environmental and manufacturing industries

317 NE 144th Street Vancouver, WA 98685
360.576.6331

Project Name:

Site Location:

Date:

Project Contact:

Turnaround Time:

Normal:

Other:

Pg 2 of 4

Test Drinking Water for Lead

Broadway Learning Center

Feb 21, 2022

T. Nadermann

Sample ID	Location/Description	Analysis	Comments
BLC-14-F	Class - 14 - Sink Faucet	Lead	EPA Method 200.8
BLC-15-F	" - 15 - "		
BLC-16-F	" - 16 - "		
BLC-18-F1	" - 18 - Sink Faucet #1		
" - " - F2	" - 18 - " - #2		
" - " - F3	" - 18 - " - #3		
BLC-19-F1	" - 19 - " - #1		
" - " - F2	" - 19 - " - #2		
" - " - F3	" - 19 - " - #3		
" - " - RR-F1	" - " - Rest - Sink Faucet #1		
" - " - " - F2	" - " - " - " - #2		
BLC-20-F	" - 20 - Sink Faucet		
BLC-C-F	Custodial " Closet		

Sampled by:

T. Nadermann
E. Wilson

Date:

Feb 21, 2022

1122

2523-21

Sterling Technologies LLC

317 NE 144th St
Vancouver, WA 98685

Project: Drinking Water - 2022

Project Number: Broadway Learning Center

Project Manager: Thomas Nadermann

Report ID:

A2B0787 - 03 14 22 0946

Chain of Custody
Field Sampling Log

A2B0787
Sterling Technologies, LLC

Providing technical consulting support to the
environmental and manufacturing industries

317 NE 144th Street Vancouver, WA 98685
360.576.6331

Project Name:

Site Location:

Date:

Project Contact:

Test Drinking Water for Lead
Broadway Learning Center
Feb 21, 2022
T. Nadermann

Turnaround Time:

Normal: ☒

Other: ☐

Sample ID	Location/Description	Analysis	Comments
BLC-N-F	Health Office - Sink Faucet	Lead	EPA Method 200.8
" - K - F1	Kitchen - Sink - #1		
" - " - F2	" - " - #2		
" - " - F3	" - " - #3		
" - ST-L-F	Staff Lounge - Sink Faucet		
" - SPR-F	Staff Rest Rm -		
" - FRR-F	Faculty Rest Rm -		
" - B-M-1	Boys Rest Rm - Middle Sink - #1		
" - B-M-2	" - " - " - #2		
" - B-N1-F1	" - North #1 - " - #1		
" - B-N1-F2	" - " - " - #2		
" - B-N2-F1	" - North #2 - " - #1		
" - B-N2-F2	" - " - " - #2		

Sampled by:

T. Nadermann
E. Wilson

Date:

Feb 21, 2022

1172
2-23-22



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Sterling Technologies LLC

317 NE 144th St

Vancouver, WA 98685

Project: Drinking Water - 2022Project Number: Broadway Learning CenterProject Manager: Thomas Nadermann

Report ID:

A2B0787 - 03 14 22 0946

APEX LABS COOLER RECEIPT FORM

Client: Sterling Technologies LLC Element WO#: A2B0787Project/Project #: Test Drinking Water for Lead - Broadway Learning Center

Delivery Info:

Date/time received: 2-23-22 @ 11:22 By: MKDelivered by: Apex ☒ Client ☐ ESS ☐ FedEx ☐ UPS ☐ Swift ☐ Senvoy ☐ SDS ☐ Other ☐Cooler Inspection Date/time inspected: 2-23-22 @ 12:50 By: MKChain of Custody included? Yes ☒ No ☐ Custody seals? Yes ☐ No ☒Signed/dated by client? Yes ☒ No ☐Signed/dated by Apex? Yes ☒ No ☐

	Cooler #1	Cooler #2	Cooler #3	Cooler #4	Cooler #5	Cooler #6	Cooler #7
Temperature (°C)	<u>11.4</u>						
Received on ice? (Y/N)	<u>N</u>						
Temp. blanks? (Y/N)	<u>N</u>						
Ice type: (Gel/Real/Other)	<u>N/A</u>						
Condition:	<u>good</u>						

Cooler out of temp? (Y/N) Possible reason why: Drinking Water / Lead TestingGreen dots applied to out of temperature samples? Yes ☒ No ☐Out of temperature samples form initiated? Yes ☒ No ☐Sample Inspection Date/time inspected: 2/25/22 @ 12:08 By: ZAMAll samples intact? Yes ☒ No ☐ Comments: ZAM 2/25/22Bottle labels/COCs agree? Yes ☐ No ☒ Comments: Container 250m BIC-20-FR ZAM 2/25/22
Grads BIC-21-F.COC/container discrepancies form initiated? Yes ☐ No ☒Containers/volumes received appropriate for analysis? Yes ☒ No ☐ Comments: ZAM 2/25/22Do VOA vials have visible headspace? Yes ☐ No ☐ NA ☒Comments: ZAM 2/25/22Water samples: pH checked: Yes ☒ No ☐ NA ☒ pH appropriate? Yes ☒ No ☐ NA ☒Comments: ZAM 2/25/22

Additional information:

Labeled by:

ZAM

Witness:

AKK

Cooler Inspected by:

ZAM

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Darrell Auvil, Client Services Manager